

APPLICATION No.: 14755

TAP CLEARED

LOCATION: 263 Rockdale Ave.OWNER: Antonio Almeida

MEASURES:

 $\frac{3}{4}$ "

L

June 29, 1912

S from

Sharp St.

~~11.0 ft.~~ 5.5 ft.

E from W line Rockdale Ave.

~~9.0 ft.~~ 9.6 ft.

N x N line house - main wall

4.5 ft. Corrected measures 7/18/95 JR

S from N line house

~~2.6 ft.~~

Jan. 3, 1975 Renewed from the main to 1 ft. inside
curb stop.

11½ ft. - $\frac{3}{4}$ " Copper tubing $\frac{3}{4}$ " Curb Stop

Caldwell Stop Box

1 wipe joint

 $\frac{3}{4}$ " x 1" Fig. 413

July 18, 1995: Renewed from main to ins. cellar (20ft ins. prop
line) Stock: 40ft $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ " curb stop
1- Caldwell stop box 1- $\frac{3}{4}$ " corporation tap (inst. new tap-old
tap was leaking) Installed new curb stop box 3ft east of old box
=====

DATE

BEF.

AFT.

REMARKS

✓

7/10/95

952800305

[illegible]

CHARGE OUTS

[illegible]

#263

APPLICATION No.: 14755

TAP CLEARED

LOCATION: Sharp Cor. Rockdale Ave.

OWNER: _____

MEASURES: 3/4"

S from

E from W line

S from N line

Sharp

Rockdale Ave.

House

11.0 ft.

9.0 ft.

2.6 ft.

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]