

APPLICATION No.: 14789

## TAP CLEARED

LOCATION: 149 Myrtle

OWNER: Wm Morley

MEASURES: 5/8"

S from	Peckham	128.5 ft.
E from W line	Myrtle	10.0 ft.
S from N line	House	3.0 ft.

4/9/86: Cleared tap. installed 1.0ft. 3/4" copper tubing  
1 - 5/8" Fig. 413 1 - 3/4x5/8 lead to cop adapt. xs.

3/2/87: Renewed from 1/2' outside curb stop to ins. cellar.  
(17 ft. ins. prop line) Stock: 27ft. 3/4" copper tubing  
1 - 3/4" curb stop 1-Caldwell stop box 1 - 3/4x5/8 lead to cop  
adapt. xs 1-3/4 x 3/4" cop to cop cplg. comp. (5' W x curb stop)

8/8/06 - Caliacco Corp. renewed from main to property line - 17 ft

DATE

BEF.

AFT.

REMARKS

4/9/86: TAP REAMED

8615-213P

8710-0045

[illegible]

## CHARGE OUTS

[illegible]