

APPLICATION No.: 14799 5/8" H lead

TAP CLEARED

LOCATION: 3982 Acushnet Ave.

OWNER: Agnes Mc Kenna

MEASURES: 5/8"

H lead

July 25, 1912

S from

Braley Rd.

410.9 ft.

W from E line

Acushnet Ave.

4.5 ft.

S from S line

House

1.5 ft.

3/23/93: Renewed from 1/2' outside curb stop to prop line

Stock: 5ft 3/4" copper tubing 1-3/4" curb stop

1- Caldwell stop box 2-3/4x5/8 lead-cop adapt.xxs

Stp. 18, 2007: N.E. Pressure Project tied service into new 12" Main.

Renewed from Main to Curb stop.

30 ft. - 3/4" copper tubing, 1 - 3/4" Curb Stop, 1 - Caldwell Stop Box.

3/26/2018: Lead service line replacement program

Contractor: P. Gioioso & sons

Type CU: Diameter 1inch, Water Pressure 59 (@meter)

Distance from main to curb stop N/A

Distance curb stop to meter 92'

Distance from curb stop to face of curb stop 3.2'

Depth of service 4.5' face to curb stop

Total length of new pipe installed 99'

Curb stop replaced NO: Size 3/4"

Corporation replaced: NO : Size 3/4"

Ball Valve Furnished YES: Size 1"

95 ft- curb stop to face of house

1.0ft- wall thickness

3ft whip

99ft - 1" copper installed

DATE

BEF.

AFT.

REMARKS

2-25-93

9312 15-92

METER HISTORY

CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

