

APPLICATION No.: 14807

TAP CLEARED ✓

LOCATION: 24 Stapleton

OWNER: J.A. Almerida

DATE

BEF.

AFT.

REMARKS

9-7&13-63

Reamed

MEASURES: 5/8"

S from	Cove	142.8 ft.
W from E line	Stapleton	9.3 ft.
S from S line	House	13.0 ft.

September 7 & 13, 1963 Renewed from main to the property line.
32 ft. of 3/4" copper tubing 1 3/4" cop. to cop. stop
1 lb. wiping solder 1 5/8" reused corporation coupling
1 Caldwell stop box, complete-long

1" Copper Service
1/15/2019 Lead Service Replacement Program
Type CU, Diameter 1in, Water pressure 100
Distance from main to curb stop (ft) N/A
Distance from curb stop to meter (ft) 18
Distance from curb face to curb stop (ft) 3
Depth of service (ft) 4.5
Total length of new pipe installed (ft) 18
Curb stop replaced: NO Corporation replaced: No
Ball valve replaced: yes size 1"

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
1-6-64		5/8	Trident	16811704					

CHARGE OUTS

