

APPLICATION No.: 14810 5/8 H lead

TAP CLEARED

LOCATION: ~~3003 Acushnet Acushnet Ave.~~OWNER: ~~Juliette Tecteau~~

MEASURES: 5/8

~~Hlead~~ **COPPER** July 17, 1912

S from Braley Rd. 1298.4 ft.

E from W line Acushnet Ave. 9.5 ft.

N from S line House 7.4 ft.

Trench dug by taker.

11/15/05 Renewed from main to property line  
 Stock: 18' of 3/4" copper tubing, 3/4" curb stop, stop box,  
 5/8 x 3/4 lead to copper adapt. xs, 5/8 x 3/4 fig. 413  
 Tap reamed

10/2/07 - NE Pressure Project - Tied service into new 12" main.  
 Renewed from main to a point 4 ft outside curb stop  
 Stock: 12 ft - 3/4" copper tubing; 1 - 3/4" x 3/4" cop to cop  
 cplg. comp. Note: This service is uner 36" water main. F. Bento

12/8/2017: Lead service line replace program

Contractor: P. Gioioso &amp; Sons

Type: CU Diamater 1 Water Pressure 65 PSI

Distance cur l stop to meter 27.9'

Distance from cur l face to cur l stop 0'

Depth of service 0.8'

Total length of new pipe installed 29.9'

Cur l stop replaced NO: Size 3/4"

Corpration replaced No Size 3/4"

Ball valve furnished YES Size 1"

DATE

BEF.

AFT.

REMARKS

11/15/05

Tap reamed

## METER HISTORY

## CHARGE OUTS

[illegible]