

APPLICATION No.: 14865

TAP CLEARED

LOCATION: 410 Ashley Blvd

OWNER:

31-313

MEASURES:

Aug 13, 1912

S from Belleville Rd 79.0'

W from E line Ashley Blvd 18.0'

S from N line house 14.5'

1" COPPER

4-9-2018: Lead service line replacement program
phase 1: TYPE CU, Diameter 1, Water Pressure 60

Contractor: P. Gioioso & Sons

Distance from main to curb stop 42.0'

Distance curb stop to meter 25.0'

Distance from curb face to curb stop 1.0'

Depth of service 3.6'

Total length of new pipe installed 70

42' public -- 28' private

Curb stop replaced: YES Size 1"

Corporation replaced: YES Size 1"

Ball Valve furnished YES Size 1"

Remarks: 42' main to curb stop

24' curb stop to house

1.0' wall thickness

3.0' whip

70' - 1" copper installed

DATE

BEF.

AFT.

REMARKS

METER HISTORY

CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST		REMARKS

lies.

