

LOCATION: 4569 Acushnet Ave.

OWNER: Anthony Costa

## MEASURES:

3/4"	L lead	Sept. 18, 1912
N from	Peckham Rd.	3326.0 ft.
E from W line	Acushnet Ave.	9.0 ft.
S from S line	House	0.6 ft.

June 4, 1975 Renewed from the main to 1 ft. from the main.

1 ft. - 3/4" Copper tubing 1 wipe joint

1" x 3/4" Fig. 413 - - -

1/18/90: Renewed from 1/2' outside curb stop to a point  
 5 ft. Stock: 6ft. 3/4" copper tubing 1-3/4" curb stop  
 1-Caldwell stop box 2-3/4x5/8 lead to cop adapt. xs

12-9-99 Renewed from 1/2' outside curb stop to a point  
 2 1/2' inside. Stock: 3 ft. - 3/4" Copper tubing,  
 1 - 3/4" Curb Stop, 1 - Caldwell Stop Box, 2 - 5/8" x  
 3/4" lead to cop. adapt. XXS.

3/12/2009 Service was previously abandoned (shot off + removed meter 9/21/05)  
 Killed service at tap on 36" water main  
 Foreman: Frank Bento

DATE BEF. AFT. REMARKS

6/4/75

Reamed

11/9/00 20004601901



## METER HISTORY

[illegible]

## CHARGE OUTS