

APPLICATION No.: 14921

TAP CLEARED ✓

LOCATION: 304 Maxfield S.E. Cor. Ash

OWNER: Catherine Branchine

MEASURES: 5/8"

E from

Ash

25.7 ft.

N from S line

Maxfield

6.0 ft.

W from E line

House

4.0 ft.

Oct. 4, 1971 Renewed from 1/2 ft. outside curb stop to property line.

7 ft. - 3/4" Copper tubing

3/4" curb stop

2 wipe joints

Stop Box

- - -

9/15/89 Drain Problem check out by Stuart
 repaired by Boucher + Maniel.

3/30/05 Silva Construction repaired broken sewer. Replaced with
 5 ft. 8" PVC; 2 Ferncoes.

7/12/2018 renewal main to meter

cast iron stop boxes box of 3/4 copper tubing 3/4 90 copper tubing

3/4" Ball Valve .75 x 3/4 x 1/2 brass bushing 3/4 copper male adapter

Daniel Perry

Ronnie Aguiar

[illegible]

This image shows a blank, aged, cream-colored page, likely an endpaper or flyleaf of a book. The paper has a slightly textured appearance with some faint smudges and discoloration, particularly along the right edge and bottom. The binding edge on the left is visible.