

14932

TAP CLEARED

LOCATION: 179 Eugenia

OWNER: Eddie Lizotte

MEASURES: 5/8"

W from	Aoushnet Ave.	254.0
S from N line	Eugenia	8.8
E from W line	House	11.0

S from Nline Eugenia 8.8

E from W line House 11.0

07/10/13 City crew repaired curbstop leak and renewed service from main to property line.

Stock: 32ft - 3/4" copper tubing; 1 - 3/4" curb stop

1 Caldwell stop box; 1 - 5/8"x3/4" Lead to cop XXS;
1 - 5/8"x3/4" fig 412

1 - 5/8"x3/4" fig 413. Tap reamed. J.Medeiros

04.12.2018 Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

1" Copper Service

Type CU, Diameter 1in, Water Pressure 59

Distance from main to curb stop (ft) N/A

Distance from curb stop to meter (ft) 15.3

Distance from curb face to curb stop (ft) 1.2

Depth of service (ft) 3.8

Total length of new pipe installed (ft) 18.3

Curb stop replaced: no Corporation replaced: no

Ball Valve Furnished: yes size 1"

DATE _____

BEF.

AFT.

REMARKS

7	10	13
---	----	----

Tap reamed

2013-2806462

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
5-28-62		5/8	Calmet	1764726					

CHARGE OUTS

