

14975

APPLICATION No.:

TAP CLEARED 84510012

LOCATION: 392 Ashley Blvd

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES:

Nov 2, 1912

S from Eugenia St 80.0'

W from E line Ashley Blvd 17.0'

S from N line house 16.0'

1" COPPER

4-9-2018: Lead service line replacement program
phase 1: TYPE CU, Diameter 1, Water Pressure 60

Contractor: P. Gioioso & Sons

Distance from main to curb stop 42.0'

Distance curb stop to meter 24.0'

Distance from curb face to curb stop 1.0'

Depth of service 3.5'

42.0' ft public

Total length of new pipe installed 69.0'

27.0' private

curb stop replaced: YES Size 1"

Corporation replaced: YES Size 1"

Ball valve furnished: YES Size 1"

remarks: main to curb stop 42'

23' curb stop to house

1' wall thickness

3.0' whip

69' total 1" copper installed

7-9-1992

9228-371

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS

