

APPLICATION No.: 14984

TAP CLEARED

LOCATION: 62 County St.OWNER: Edward & Clara KishertMEASURES: 3/4" H lead Nov.13,1912E from County St. 42.0 ft.S from N line Nelson St. 8.0 ft.W from E line house 19.0 ft.

8/20/99 Renewed from main to a point 2 ft. front of main.

2 ft. - 3/4" copper tubing 1 - 3/4" x 3/4" lead to cop adapt XS

1 - 3/4" corportation tap, 1 - 6" x 3/4" Service saddle.

Note: Service was not complete because car was parked on tap of service.

10/03/13 City crew renewed service from main to curb stop

Stock: 30ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1 - Caldwell stop box;

1 - 3/4"x3/4" lead to cop Adapt; Tap reamed

J.Medeiros

1/11/2019: Lead service line replacement program phase 1

Contractor: P.gioioso & sons, TYPE CU, Diameter 1,

Water Pressure 90

Distance from main to curb stop N/A

Distance curb stop to meter 15'

Distance from curb face to curb stop 2'

Depth of service 5'

Total length of new pipe installed 15'

Curb stop replaced N/A Size N/A

[illegible]

CHARGE OUTS

[illegible]

[illegible]

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS

