

APPLICATION No.: 15024

TAP CLEARED

✓

LOCATION: 93 Scott St.

OWNER: Frank J. Carvalho, Et Ux

DATE

BEF.

AFT.

REMARKS

4-14-71

Reamed

MEASURES:

5/8"

H lead

Dec.19,1912

E from

Crapo St.

144.0 ft.

S from N line

Scott St.

8.5 ft.

E from W line

house

10.0 ft.

April 14, 1971 Renewed from the main to 2 ft. from the main.

2 ft. of 3/4" copper tubing 1 wipe joint

1 3/4" x 3/4" Hays fig. 413

July 7, 1972 Renewed from the main to the curb stop.

24 ft. of 3/4" copper tubing

1" Copper Service

07/08/2019 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) N/A

Distance from curb stop to meter (ft) 20

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 4

Total length of new pipe installed (ft) 20

Curb stop replaced: No Corporation replaced: No

Ball valve replaced: Yes size 1"

[illegible]

CHARGE OUTS

9-27-6

155.

--	--

--

--	--

[illegible]

--	--	--

[illegible]