

APPLICATION No.: 15053

TAP CLEARED

LOCATION: 33 Ellen St.OWNER: Albert L. BourqueMEASURES: 5/8" H lead Jan.22,1913W from Cleveland St. 304.5 ft.S from N line Ellen St. 9.0 ft.E from W line house 1.0 ft.

Dec. 22, 1976 Renewed from the main to a point $5\frac{1}{2}$ ft.
from the main.

$5\frac{1}{2}$ ft. - $\frac{3}{4}$ " Copper tubing $\frac{5}{8}$ " x $\frac{3}{4}$ " lead conn.
 $\frac{5}{8}$ " x $\frac{3}{4}$ " Fig. 413

6/5/78: Renewed from 6" outside curbstop to inside cellar
wall. 19 ft. - $\frac{3}{4}$ " copper (11 ft. ins.); $\frac{3}{4}$ " curb stop;
 $\frac{5}{8}$ " x $\frac{3}{4}$ " lead to cop. adapt. XXS; Caldwell stop box;

12/1/86: Service hit by DPW repaired from 12.0ft. south of curb
stop to 15.0ft. south of curb stop in street. Stock: 3.0ft. $\frac{3}{4}$ "
copper tubing 1- $\frac{3}{4}$ " curb stop 2- $\frac{3}{4}$ x $\frac{5}{8}$ lead to cop adapt. xxs

Street reconstruction Sept 19,1997:

Renewed from main to curb stop

Stock: 24ft $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ " curb stop
old caldwell stop box 1- $\frac{3}{4}$ x $\frac{5}{8}$ Fig 413

DATE BEF. AFT. REMARKS

12/22/76

Reamed

9/19/97: tap reamed

[illegible]

CHARGE OUTS

[illegible]