

APPLICATION No.: 15058

TAP CLEARED ✓

LOCATION: 575 Union N.W. Cor. Rotch

OWNER: J. Boyle

MEASURES: 5/8"

W from	Rotch	15.0 ft.
S from N line	Union	9.0 ft.
W from E line	house	10.0 ft.

-----  
 April 7, 1972 Renewed from 6" outside the curb stop to the property line.

6 1/2 ft. of copper tubing 1 3/4" Hays curb stop  
 2 wipe joints  
 -----

6-18-98 Biszco Cont renewed service from the newly installed. 10" ductile main to a point 2 ft from the main. Stock supplied by Contractor: 2 ft - 3/4" Copper tubing, 1 - 5/8" x 3/4" lead to cop. adapt. XXS, 1 - 3/4" Corporation tap. Cont to maintain cut.

2-22-99 M. Pavao Const. renewed from main to prop. line. Stock: 38 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop 1 - Caldwell Stop Box, 1 - 5/8" x 3/4" lead to cop. adapt. XS, M. Pavao Cont. to maintain cut.  
 -----

2/14/08 - Owner charged \$100 (shut off - overtime); pipes broken; house vacant; shut off in cellar - could not shut off at curb stop; curb stop to be replaced, called into Fire Dept. Foreman: Danny Perry  
 -----

2/27/08 - City replaced curb stop, so owner could shut off for repairs. Owner charged \$30 for shut-off. Foreman: Dennis Monty  
 1 Caldwell stop box

DATE

BEF.

AFT.

REMARKS

2/21/08 10:15 2008-0703521

[illegible]

## CHARGE OUTS

[illegible]