

APPLICATION No.: 15079

TAP CLEARED

LOCATION: 127 Brooklawn ~~Ave~~ St.

OWNER: Elsie Darion

MEASURES: $\frac{5}{8}$ " *Lead* 03-05-1913
 N from N line Brooklawn Ave. 39.5 ft.
 W from E line Vernon 6.5 ft.
 S from line House 12.5 ft.

April 11, 1980: Renewed from main to a point 3.0 ft. from main.

Warren Bros. broke this service.

3.0 ft. - $\frac{3}{4}$ " copper1- $\frac{5}{8}$ " x $\frac{3}{4}$ " lead-cop. adapt. XXS1- $\frac{5}{8}$ " x $\frac{3}{4}$ " Fig. 413 Tap Reamed

 8/25/11 - City crew renewed water service from main to property line

33 ft - $\frac{3}{4}$ " copper tubing; 1 - $\frac{3}{4}$ " curb stop;1 Caldwell stop box; 1 - $\frac{5}{8}$ " x $\frac{3}{4}$ " Fig 413; 1 - $\frac{5}{8}$ " x $\frac{3}{4}$ " lead to cop adapt xxs; Tap cleaned

Foreman: Frank Bento

DATE

BEF.

AFT.

REMARKS

4/11/80

Reamed

8/25/11

12:30 2011-3508403

[illegible]