



Sept. 9,1953, ser. leak, renewed from main to 1 ft. from main using 1 ft. 3/4" cop.tubing Tap reamed. 1 wiped joint.

3/9/83-Renewed from 6" outside curbstop to a point 5.5 ft. from curb stop. 6.0 ft.-3/4" copper, 1-3/4" curb stop, 1- stop box, 2-5/8" x3/4" lead-cop. adapt. XXS.

2-12-90 renewed from main to curb stop Stock:

20 ft. 3/4" copper tubing, new tap on at new remain, street cut: 10x3 warrenite & 6x3 near curb loader compressor.

9/5/89 REnewed from newly inst. 6" ductile main to a point 1ft. Brito Const. supplied all stock. 1 3/4 corp tap 1ft 3/4 corpus tubing 15/8 x 3/4 und to cop adapt. 2x