

APPLICATION No.: 15109TAP CLEARED 87/5-1106LOCATION: 143 JamesOWNER: Richard GoulartMEASURES: 5/8"

01/01/1913

N from

Court

174.0 ft.

E from W line

James

7.0 ft.

N from S line

House

6.8 ft.

4/7/87: Renewed from main to property line. Stock: 13ft. 3/4"
copper tubing 1-3/4" curb stop 1-Caldwell stop box
1 - 3/4 x 5/8 lead to cop adapt. xs 1-3/4x5/8 Fig.413

9/11/08 - Perrina Construction (Contract #4) renewed service

from main to a point 3 ft

3 ft - 1" copper tubing; 1 - 1" x 3/4" copper reducer

Inspected by Tim Ives, CDM

DATE

BEF.

AFT.

REMARKS

4/7/87:

TAP

REAMED

[illegible]

CHARGE OUTS

[illegible]