

APPLICATION No.: 15123

TAP CLEARED ✓

LOCATION: 333 Mill, Cor. Tremont

OWNER: Sidney T Kniffon

MEASURES:

5/8"

Lead

04/15/1913

W from

Tremont

13.4 ft.

S from N line

Mill

6.0 ft.

W from E line

House

11.7 ft.

Dec. 20, 1957 Renewed from the curb stop to a point
 3½ ft. inside curb stop.
 3½ ft. - 3/4" Copper tubing 2# wiping solder

March 14, 1957 Renewed from main to a point 2 ft. from
 main.
 2 ft. - 3/4" Copper tubing 3/4" Cop to ipf cplg.
 1 lb. wiping solder

Jan. 4, 1980: Renewed 6" outside curb stop to 4 ft. inside.
 4.6 ft. - 3/4" copper
 1-Caldwell stop box 1-3/4" curb stop
 2-5/8" x 3/4" lead-cop. adapt. XXS

5/20/11 - City crew renewed water service from main
 to property line
 22 ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1 Caldwell
 stop box; 1 - 5/8" x 3/4" Fig 413; 1 - 5/8" x 3/4" lead
 to cop adapt xxs; tap cleaned. Foreman: Bill Days

DATE

BEF.

AFT.

REMARKS

4/14/11

12:00

2011-160 1388

[illegible]

CHARGE OUTS

[illegible]