

APPLICATION No.: 15126

TAP, CLEARED

LOCATION: 70-72 OCEAN ST

OWNER: STEVE MACEDO

MEASURES: 5/8"

S from UNION ST 107.8ft

W from E line OCEAN ST 7.0ft

S from N line BLDG 2.0ft

June 24, 1996:

Renewed from main to prop line

Stock: 24ft 3/4" copper tubing 1-3/4" curb stop

1- Caldwell stop box 1-3/4x5/8 lead-cop adapt. xs

1-3/4x5/8 Fig 413 1-3/4" corporation tap

1- ADams service saddle wrap around 6 x 3/4

=====

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 15126

TAP CLEARED

LOCATION: 70-72 Ocean

OWNER: Alram Boomer

STEVE MACEDO

MEASURES:	5/8		
	S from	Union	107.8 ft.
	W from E line	Ocean	7.0 ft.
	S from N line	Bldg.	2.0 ft.

April 2, 1974 Renewed from 6" outside curb stop to property line.

7½ ft. - 3/4" Copper tubing 3/4" Curb stop
2 wipe joints Stop Box

8/12/87: Service was broken by Frank Corp when installing telephone conduit cable. We fixed service water line 11.6 ft. from curb stop box. Will be cement duck over the service.-----

Stock:-

3.0 ft. - 3/4" copper tubing 1 - 3/4" curb stop buried (used as cplg.)
2 - 3/4" x 5/8" lead to cop adapt XS

11/24/89: Renewed from main to a point 3.5 ft.

Stock: 3.5 ft. 3/4" copper tubing
1-3/4 x 5/8 lead to cop adapt. xs 1-3/4" corporation tap

NOTE: WHILE DIGGING FOR 69 OCEAN ST. BLOCKED TAP FROM
CEMENT LINERS, BACKHOE PULLED TAP FROM MAIN NEW TAP WAS RETREAD &
SERVICE PATCHED.

[illegible]