

APPLICATION No.: 15159 3/4" L lead

TAP CLEARED 84-32-0617 ✓

LOCATION: 145-47 Adams St.

OWNER: Michel Sheehaw

MEASURES:

3/4"

L lead

May 17, 1913

W from

Mt. Pleasant

162.0 ft.

S from N line

Adams

9.0 ft.

E from W line

House

10.0 ft.

Jan. 6, 1977 Renewed from the main to a point 1 ft.
from the main. Tap Leak.

1 ft. - 3/4" Copper tubing

3/4" x 3/4" lead to cop. conn. 3/4" x 3/4" Fig. 413

Aug. 7, 1984 Renewed from 1/2' outside curb stop to
prop line Stock: 6 ft. 3/4 copper tubing 1 curb
stop 1 Caldwell stop box 2 5/8 x 3/4 lead to cop
adapt. XXS

DATE

BEF.

AFT.

REMARKS

1/6/77

Reamed

METER HISTORY

CHARGE OUTS

[illegible]