

APPLICATION No.: 15188

## TAP CLEARED

LOCATION: 23 Jouvette St

OWNER:

31-313

MEASURES:

May 29, 1913

W X County St

218.0 ft

S X N Line Jouvette St

9.0 ft

E X W Line House

2.0 ft

1" Copper Service

09/18/2018 Lead Service Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) 23.8

Distance from curb stop to meter (ft) 13

Distance from curbface to curb stop (ft) 1.3

Depth of service (ft) 3.7

Total length of new pipe installed (ft) 23.8

Curb stop replaced: yes size 1"

Corporation replaced: yes size 1"

Ball valve replaced: no size 3/4"

Remarks: 1-3/4" union installed where shown

DATE

BEF.

AFT.

REMARKS

# METER HISTORY

| DATE | SET OUT | SIZE | MAKE | NUMBER | READING | TEST |  |  | REMARKS |
|------|---------|------|------|--------|---------|------|--|--|---------|
|      |         |      |      |        |         |      |  |  |         |
|      |         |      |      |        |         |      |  |  |         |

## CHARGE OUTS

