

TAP CLEARED 8323-0084

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

10/9/04 830 AM 2004-410 9869

W from N line	Ashley Blvd.	159.0 ft.
S from E line	Holly	9.0 ft.
W from E line	House	11.0 ft.

JAN 17 1983 --Renewed from 6" outside curbstop to the  
line. 8.0 ft.-3/4" copper; 3/4" curb stop; stop box;  
2- 3/4" x 3/4" lead-cop. adapt. XXS;

10/8/04 Renewed from main to curb stop. Stock: 25 ft. 3/4" copper tubing; 3/4" curb stop; Caldwell stop box; 3/4" Corporation tap. Repaired 6" sewer service on sidewalk. Stock: 8 ft. 6" PVC pipe; 2 - rubber cplgs.; 6" clay-PVC

[illegible]

## CHARGE OUTS

[illegible]