

APPLICATION No.: 15247 5/8" L lead

TAP CLEARED

LOCATION: 25-27 Atlantic St.

OWNER: Edward J. Foster

MEASURES: 5/8"

L lead

June 27, 1913

S from

Union

251.0 ft.

E from W line

Atlantic

7.0 ft.

S from N line

House

12.0 ft.

Laid in trench excavated for drain.

Feb. 26, 1962 Renewed from $\frac{1}{2}$ ft. outside curb stop to property line.

9 ft. - $\frac{3}{4}$ " copper tubing; 2# wiping solder;

1 Caldwell stop box, complete (Long)

1/12/04 Renewed from main to a point 3 ft. front the main.

Stock: 3 ft. $\frac{3}{4}$ " copper tubing; $\frac{5}{8}$ " x $\frac{3}{4}$ " lead-cop adapt. XXS

$\frac{5}{8}$ " x $\frac{3}{4}$ " Fig. 413 Tap reamed

Also: Replaced section (3 ft. section) of sewer 6" house service under water main Stock: 3 ft. 6" PVC; 2 - rubber cplgs., PVC-clay

8/20/07 - Renewed from main to a point 9 ft.

Stock: 9 ft - $\frac{3}{4}$ " copper tubing; $\frac{3}{4}$ " curb stop; Caldwell stop box; $\frac{5}{8}$ " x $\frac{3}{4}$ " Fig. 413. Tap reamed. Foreman: D. Monty

DATE

BEF.

AFT.

REMARKS

1/12/04

Tap reamed

METER HISTORY

CHARGE OUTS

[illegible]