

APPLICATION No.: 15274

TAP CLEARED 9106-0828 ✓

LOCATION: 597 Maxfield

OWNER: John Gonsalves

MEASURES: 5/8"

E from

Beech

115.7 ft.

S from N line

Maxfield

7.0 ft.

W from E line

House

0.5 ft.

2/5/91: Renewed from 1/2' outside curb stop to a point
4 ft. Stock: 4.5 ft. 3/4" copper tubing
1- 3/4" curb stop 1-Caldwell stop box
2- 3/4x5/8 lead to cop adapt. xs=====

Dec. 13, 1995: REnewed from main to a point lft
Stock: 1ft 3/4" copper tubing 1-3/4x5/8 lead-cop adapt. xs
1- 3/4 x 5/8 Fig 413
=====

9/4/08 - West End Water Main Rehab Contract # 4 - Perrina Const.

Renewed water service from main to property 1 line
25 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" curb stop;
1 - 1" x 3/4" reducer. Inspected by Tim Ives, CDM

DATE

BEF.

AFT.

REMARKS

12/13

9550-01928

12/13/95: tap reamed

[illegible]