

APPLICATION No. 15322 5/8" L lead

TAP CLEARED

LOCATION: 205 Campbell St.

DATE

BEF.

AFT.

REMARKS



OWNER: Wm. T. & F.M. H. Eutwistle

MEASURES: 5/8"

L lead

08-13/1913

E from

Park

56.6 ft.

S from N line

Campbell

7.0 ft.

W from E line

House

11.0 ft.

9/8/97: tap reamed

1/12/09 8:00AM 2009-030 0316

Sept. 5, 1969 Renewed from 6" outside of the curb stop to a point 4 ft. inside of the curb stop.
 4½ ft. - 3/4" copper tubing; 1-3/4" Hays curb stop;
 2 wipe joints;

Feb. 27, 1975 Renewed from the curb stop to inside cellar.

17½ ft. - 3/4" Copper tubing (11 ft. inside)
 Acushnet Stop Box Same curb stop

Sept 8, 1997: Renewed from main to a point 1ft outside of main Stock: 1ft 3/4" copper tubing 1-3/4x5/8 lead-cop adapt 1ft outside of tap 1-3/4x5/8 Fig 413
 XXXS

=====

1/12/09 - City crew renewed service from 1/2 ft outside curb stop to a point 1 ft - due to curb stop leak
 1 ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1 Caldwell stop box; 1 - 3/4" x 5/8" lead to cop adapt. Foreman: Jesse Velez

METER HISTORY

[illegible]

CHARGE OUTS