

APPLICATION No.: 15385 5/8"

# TAP CLEARED

LOCATION: 293 Collette St.

OWNER: Meleda Mailloux

MEASURES: 5/8"

W from Ashley Blvd. 320.5 ft.

S from N line                      Collette                      9.0 ft.

W from E line                      House                      14.0 ft.

2/25/80: Renewed from main to 2 ft. from main. 2 ft.-3/4"

copper;  $3/4'' \times 5/8''$  Fig. 413;  $5/8'' \times 3/4''$  lead-cop. adapt.

XS - - - - -

2/26/80: Renewed from 6" outside curb stop to prop. line

10 ft.-3/4" copper; 3/4" curb stop; Caldwell stop box;

2-5/8" x 3/4" lead-cop. adapt. XS

2/27/80: Renewed from property line into cellar. 13.5 ft

3/4" copper; 3/4" x 3/4" cop.-cop. comp. cplg.

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

2/25/80

Reamed

2 ft. of	6" drain pipe
broken. Rep. by	Drain Dept.

This service only 2 ft. deep.

[illegible]