

1 Morton **RD.**

APPLICATION No. 15392 11/2" Galv.

TAP CLEARED

No. Rochester Rd. N.E. Cor. Middleboro Rd.

LOCATION:

~~FREETOWN~~

DATE

BEF.

AFT.

REMARKS

OWNER: (Plot 221 - Lot 68)

(L.H. #10)

31-313

Measures

MEASURES:

For Sketch see Back of Card

This service taps Air Valve on 48 Steel Main
South of Middleboro Rd. At Station 43+23.4

Nov. 1935: This Service connected to 48 " C.I.
With A 1" tap (See Sketch)

7-5-1950: New from tap to inside meter box
Using 7.5ft copper

8-6-1957: service leak repaired leak in 1" service
on outlet end of meter using 1.0ft -1" Copper
Type K Soft

11-21-1958: Ser. leak renewed from a point 1.0ft
from outlet of meter to a point 3.0ft from outlet
of meter using 2.0ft-1" coppertub, 1-1" Cplg.

[illegible]

soft

