

APPLICATION No.: 15441TAP CLEARED 8/6/32 - 0061LOCATION: 50-52 OceanOWNER: John DalombaMEASURES: 5/8

N from Arnold 246.0 ft.

W from E line Ocean 7.0 ft.

S from N line House 1.6 ft.

-----  
November 29, 1960 Renewed from  $\frac{1}{2}$  ft. outside curb stop to 2 ft.  
inside curb stop.

2  $\frac{1}{2}$  ft. of  $\frac{3}{4}$ " copper tubing  
-----

8/4/86: Renewed from main to a point 1 ft. Stock: 1 ft.  $\frac{3}{4}$ "  
copper tubing 1 -  $\frac{3}{4}$ x $\frac{5}{8}$  lead to cop adapt. xs 1 -  $\frac{3}{4}$ x $\frac{5}{8}$   
Fig. 413  
=====

11/13/02: Renewed from main to property line; 25 ft. -  $\frac{3}{4}$ " copper  
tubing; 1 -  $\frac{3}{4}$ " curb stop; 1 - caldwell stop box; 1 -  $\frac{5}{8}$ x $\frac{3}{4}$  lead  
to cop. adapt. XS; 1 -  $\frac{5}{8}$  x  $\frac{3}{4}$  Fig. 413; tap reamed  
=====

DATE BEF. AFT. REMARKS

8/4/86: TAP REAMED

11/14/02 8:30 AM 2002-460-3174

[illegible]

## CHARGE OUTS

[illegible]