	APPLICATION No.: 15531			TAP CLEARED					
LOCATION:	542	Union S.E. Cor.		DATE	BEF.	AFT.	REMARKS		
OWNER:	Robert S Weaver						9133 45768-16		
MEASURES:				8/22/91: TAP REAMED					
	E from S line E from W line	James Union house	90.2 ft. 8.5 ft. 15.4 ft.						
8/22/91: Renewed from main to prop line Stock: 17ft. 3/4" copper tubing 1-3/4" curb stop 1- Caldwell stop box $1-3/4x5/8$ lead-cop adapt.xxs 1- $3/4x5/8$ Fig.41 $\frac{3}{2}$ ===================================									
Corrected Measures - July 6, 1992 E x E line James St. 19.0 ft. N x S line Union St. 9.0 ft. W x E line house 9.5 ft. N x N line house (body) 16.0 ft.									
6-15-98 Biszko Cont renewed service from the newly installed 10" ductile main to a point from the main. Stock supplied by Contracto 2 ft - 3/4" Copper tubing, 1 - 3/4" x 3/4" cop to cop cplg., comp. 1 - 3/4" Corporation tap. Contarctor to maintain cut.									
*									

CH	IAR	GE	OU	TS
-				

METER HISTORY									
DATE	SET	SIZE	MAKE	NUMBER	READING		TEST		REMARKS
11/13/5		5/8	Hersey	637067					
±±/ ±0/ 0	,	0,0	1101 56 9	301001					
			*						,
			4,						1
			6						
								·	
			- 7						