

APPLICATION No.: 15544

LOCATION: 166 CLIFFORD ST.

OWNER: Paul Ledoux

31-313

Measures:	5/8"		
	E from	Ashley Blvd	154'
	N from S line	Clifford	9'
	E from W line	House	9.8'

1" Copper Service

09/13/2022 2022 Water main improvement program

Contractor: C. Naughton Corp.

Type CU Diameter 1"

Distance from main to curb 9'

Distance from curb stop to meter 20.5'

Distance curb face to curb stop 1.50

Depth of Service 4.5'

Total length of new pipe installed 29.50'

Curb Stop replaced yes size 1"

Corporation replaced yes 1"

Ball Valve replaced yes N/A

Remarks: Type C- 1" Copper to meter

TAP CLEARED

DATE _____

BEF.


AFT.

REMARKS

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS



CLIFFORD ST.