

APPLICATION No.: 15573

TAP CLEARED

LOCATION: 241 Hillman, Cor. Park

OWNER: F Rodriquds

MEASURES:

5/8"

W from

Park

26.0 ft.

S from N line

Hillman

9.0 ft.

E from W line

House

2.7 ft.

Sept. 27, 1975 Renewed from 4 ft. outside curb stop
to property line.

12 ft. - 3/4" Copper tubing 3/4" Curb Stop

2 - 3/4" x 5/8" lead to copper adaptor XS

- - -

May 31, 1977: Renewed from main to 2 ft. in front of main. 2 ft.-
3/4" copper; 3/4" x 3/4" Figure 413; tap reamed; 5/8" x 3/4" lead to
copper adapt. XS

4/26/02 While replacing leads on Hillman St. this service has been paved by Park St. Job.
Possible service was renewed during Park St. job.

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]