APPLICATION No.: 15621	TAP CLEARED			
LOCATION: 207 Whitman St	DATE	BEF.	AFT.	REMARKS
OWNER:				
MEASURES; E X Bowditch S X N Whitman St W X E House 1" Copper Service 4/30/2018 Lead Service Line Replacement Program Phase 1, Contractor P Gioioso & Son Type CU, Diameter 1in, Water pressure 71 Distance from main to curb stop (ft) 21.6 Distance curb stop to meter (ft) 20.8 Distance from curb face to curb stop (ft) 1.5 Depth of service (ft) 3.5 Total length of new pipe installed (ft) 42.4 Curb stop replaced: Yes size 1" Corporation replaced: Yes size 1" Ball valve replaced: Yessize 1" Remarks: 1-3/4" union installed 1.0 ft from curb stop				

