

APPLICATION No.: 1566

TAP CLEARED

LOCATION: 16 Crapo St.

DATE

BEF.

AFT.

REMARKS

OWNER: Joseph V. Sylvia

1/3/79

Reamed

MEASURES: 5/8" H lead Oct. 13, 1873
N from South St. 19.0 ft.
W from E line Crapo St. 6.0 ft.
N from S line house 7.4 ft.

Nov. 18, 1964 Renewed service from 6" outside curb stop to meter
inside cellar 12 ft. 3/4" copper tubing
3/4" cop. to cop. stop, fig. 415 1 lb. wiping solder

1/3/79: Renewed from main to curb stop. 23 ft. - 3/4" copper;
1/2" x 3/4" Fig. 413;

4/13/15 city crew repaired tap leak, renewed from
main to a point 1 ft stock: 1' 3/4" cop tubing,
1 3/4 cop tubing, 1 3/4 x 3/4 cop to cop coupl
1 1/2 x 3/4 " fig 413 tap reamed

[illegible]

CHARGE OUTS

[illegible]