

APPLICATION No.: 15691

LOCATION: 138 Aquidneck St

TAP CLEARED

OWNER:

31-313

MEASURES: 5/8" LEAD

E x E Brock Ave 418.4'
N x S Aquidneck St 9.0'
W x W House 1.5'

10/9/1979: Renewed from 6" outside cur l stop to prop
line. STOCK: 7' - 3/4" copper tubing 3/4" cur l stop;
caldwell stop box; 2- 5/8" x 3/4" LEAD-COP ADAPT. XXs

NEW CARD TYPE BECAUSE COULD NOT FIND ORIGINAL::

3/30/2020: RJ CANESSA RENEWED CURB STOP, TO METER with
3/4" COPPER SERVICE. - INSPECTED BY ANTONIO LEMOS

9/29/2020: DPI / Aaron Almond- replaced lead water
service from main to meter -- EMERGENCY MAIN BREAK
38ft of 3/4" copper tubing , 1- 3/4" female corp
adapter, 1-cur l stop valve, 1 cast iron cur l stop box,
1- 3/4" ball valve, 1- 3/4" propress male adapter, 1- 3/4" propre
s290, 1-3/4" x 1/2" brass flushing, 1- 1/2" female thread

DATE

BEF.

AFT.

REMARKS

METER HISTORY

[illegible]

CHARGE OUTS

[illegible]