

APPLICATION No.: 15741-1"

TAP CLEARED

LOCATION: N.W. Cor. 141 Allen St. & Orchard St.

OWNER: Lena Abrams

MEASURES: 1" Copper May 19, 1914

E from W line	Orchard St.	2.4 ft.
S from N line	Allen St.	5.3 ft.
E from E line	House	9.8 ft.

June 11, 1974 Relocated service from the old 4" main to the new 16" main.

✓ Renewed from the 16" main to a point 6" outside curb stop.

The old tap was shut off at the main 4" And abandoned.
26 ft. - 1" Copper tubing 1" corporation
1" x 1" cop to cop Dresser style 88 cplg.

- - -

✓ NOTE: This service is now 1" copper from the 16" main to inside cellar.

Oct. 20, 1995:

Cement lining plugged tap. Renewed from main to a point 1ft

Stock:

1ft - 1" copper tubing - by city 1-1"x1" cop-cop cplg.comp

by city 1-1" corporation tap-supplied by Walsh Const.

Walsh Const. will maintain street cut

Insp. L Souza

METER HISTORY

[illegible]

CHARGE OUTS

APPLICATION No.: 15741

TAP CLEARED

LOCATION: 141 Allen St.

OWNER: Lena Abrams

MEASURES: 1" Copper May 19, 1914

E from W line Orchard St. 2.4 ft.

S from N line Allen St. 5.3 ft.

E from E line house 9.8 ft.

Sept. 8, 1964 Renewed from a point 45 ft. outside curb
stop to a point 55 ft. outside curb stop

10 ft. 1" copper tubing

2 lbs. wiping solder

1 1" copper coupling, A-1552

250 Compressor: 2 hrs.

2 sidewalkcuts: 5' x 5' x 5' x 5' Cement

Abraham

Breton

118163

Renewed from 7 ft. inside curb stop to inside cellar.
✓ with 1" copper. (refer to service leak cards for more
information) (11) cards

— — —

✓ Jan. 5, 1970 Renewed from 6" outside curb stop to 6½' inside curb stop.
7 ft. - 1" copper tubing; 1-1" Hays curb stop; 1# wiping solder; 1-1" cop to cop cplg.; Caldwell stop box;

— — —

METER HISTORY

CHARGE OUTS

[illegible]