

APPLICATION No.: 15744

TAP CLEARED ✓

LOCATION: 505 Sawyer

OWNER: Eva Tuikaj

205-270

MEASURES: 3/4"

E from	Summer	125.0 ft.
S from N line	Sawyer	8.5 ft.
E from W line	House	9.0 ft.

March 16, 1977 Renewed from 6" outside curb stop to the property line.

7½ ft. - 3/4" Copper tubing 3/4" curb stop  
Caldwell Stop Box 2 - 5/8" x 3/4" lead to cop.  
adapt. XXS

8/20/93: Renewed from main to ins.cellar (16ft ins.prop line)  
Stock: 48ft 3/4" copper tubing 1-3/4" curb stop  
same stop box 1-3/4x3/4 Fig 413

=====

6/2003 Renewed from new 8" main to a point 2 ft.  
Stock: 2 ft. 3/4" copper tubing; 3/4" x 3/4" cop-cop  
cplg., comp.; 3/4" corporation tap

-----

9/14/04 Service pulled by gas company. Repaired water service  
Renewed from main to a point 2.0 ft. Stock; 2 ft. 3/4" copper tubing;  
3/4" curb stop; 3/4" x 3/4" cop-cop cplg., comp.

DATE

BEF.

AFT.

REMARKS

8-20-93

93345961

8/20/93: tap reamed

[illegible]