

APPLICATION No.: 15788 5/8" L lead

TAP CLEARED ✓

LOCATION: 3932 Acushnet Ave.

OWNER: Estella V. Westgate ✓

MEASURES: 5/8"

~~L lead~~ COPPER June 8, 1914

N from Stop box at 3906 Acushnet Ave. 250.3 ft.

W from E line Acushnet Ave. 7.5 ft.

S from S line House 2.0 ft.

S from Braley Rd. 926.3 ft.

9/26/07 - NE Pressure Project - tied service into new 12" main
 Renewed 3/4" copper service from main to property line

Stock: 34 ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1 caldwell
 stop box; 1 - 5/8" x 3/4" lead to cop adaptor, xxs. F. Bento

3/27/2018: Lead service line replacement program:

contractor: P. Gioioso & sons

type CU, Diameter 1, Water Pressure PSI 58 @ meter

Distance from main to cur l stop N/A

Distance curB stop to meter 59'

Distance from cur l face to cur l stop 6.8'

Depth of service 4.8'

Total length of new pipe installed 62'

cur l replaced NO: Size 3/4"

corporation replaced NO: Size 3/4"

Ball valvew furnished: YES size 1"

58ft-cur l stop to face of house

1ft-wall thickness

3ft-whip

63ft- 1" copper installed

DATE

BEF.

AFT.

REMARKS

METER HISTORY

CHARGE OUTS

| DATE | SET OUT | SIZE | MAKE | NUMBER | READING | TEST | | REMARKS |
|------|------------|------|------|--------|---------|------|--|---------|
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

