

APPLICATION No.: 15789

TAP CLEARED

LOCATION: 108 Swift

OWNER: M Gones

MEASURES:

5/8"

E from

Dartmouth

144.0 ft.

N from S line

Swift

8.5 ft.

E from W line

House

17.0 ft.

10/28/05 Renewed from main to inside cellar (10')

Stock: 24' of 3/4" copper tubing, 3/4" curb stop, stop box,  
5/8 x 3/4 Fig. 413 Tap reamed3/10/06 Sewer Repair: Replaced 6' of broken clay pipe with 6'  
of pvc

DATE

BEF.

AFT.

REMARKS

10/28/05

Tap reamed

[illegible]

## CHARGE OUTS

[illegible]