

LOCATION: 103 Beetle St.

OWNER: Eugene Boisvert

MEASURES: 5/8" H lead June 12, 1914
 E from Ashley Blvd. 129.0 ft.
 S from N line Beetle 8.8 ft.
 W from E line House 7.2 ft.

7/26/82: Renewed 6" outside curbstop to 3.0 ft. inside
 curb stop. 3.5 ft. - 3/4" copper; 3/4" curb stop; stop box;
 2- 5/8" x 3/4" lead-cop. adapt. XXS;

- - - - -

12/20/10 - Found water shut off at curb stop when
 repairing emergency curb stop leak

12/20/10 - City crew renewed water service from 1/2 ft
 outside curb stop to property line
 7 ft - 3/4" copper tubing; 1 - 3/4" curb stop;
 1 Caldwell stop box; 2 - 5/8" x 3/4" lead-cop adapt xxS
 Foreman: F. Fernandez

3/28/12 - City crew renewed water service from main
 to curb stop
 23 ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1 Caldwell
 stop box; 1 - 5/8" x 3/4" Fig 413; Tap cleaned
 Foreman: Danny Perry

DATE

BEF.

AFT.

REMARKS

12/20/10

2010-5200492

METER HISTORY

[illegible]

CHARGE OUTS