

✓ APPLICATION No.:

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

31-313

MEASURES: W X Bowditch St 78.0 ft
N X S Whitman St 8.5 ft
E X W House 10.0 ft

1" Copper Service 4/25/2018

Lead Service Line Replacement

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 65

Distance from main to curb stop (ft) 9.1

Distance curb stop to meter (ft) 19.3

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 3.5

Total length of new pipe installed (ft) 28.4

Curb stop replaced: Yes size 1"

Corporation replaced: Yes size 1"

Ball valve replaced: Yes size 1"

[illegible]