

APPLICATION No.: 15842

TAP CLEARED 8540-1

LOCATION: 160 James

OWNER: C. Guisti

MEASURES: 5/8"

01/01/1914

S from

Elm

116.4 ft.

W from E line

James

7.0 ft.

N from S line

house

11.4 ft.

10/1/85: Renewed from 1 ft. outside curb stop to a point 5 ft.

Stock:

6 ft. 3/4" copper tubing 1 - 3/4 Curb stop 1 - Caldwell stop
box 2- 3/4x5/8 lead to cop adapt. xs

=====

11/30/06 Renewed from main to inside cellar. (12 ft. inside property line)

Stock: 36 ft. 3/4" copper tubing; 3/4" curb stop; Caldwell stop box; 5/8" x 3/4"

Fig. 413 Tap reamed

Bento

.....

9/11/08 - Perrina Construction West End Water Rehab Contract #4
Renewed service from main to a point 6 ft inside curb stop

23-ft. - 1" copper tubing; 1 - 1" curb stop; 1 - 1" Corporation tap;
1 - 1" x 3/4" reducer. Inspected by Tim Ives, CDM

[illegible]

CHARGE OUTS

[illegible]