

APPLICATION No.: 15852

## TAP CLEARED

LOCATION: 567 Rear S<sup>o</sup>. First

OWNER: John De Mello

MEASURES: 3/4"

CLEAR ELECTRIC

N from	Rivet	253.4
W from Eline	Second	6.6
N from N line	438-440 Second	5.6

October 9, 1974 Renewed from 6" outside curb stop to property line.

9 ft. - 3/4" Copper tubing 3/4" Curb stop  
2 wipe joints Caldwell Stop Box-----  
February 11, 1966 Tap Reamed. 1 5/8" reused corporation cplg.  
-----Nov. 5, 1991 Request of Div. Min. Housing - Mr. Rawley  
house flooding leak inside - Blew out box with compressor *com gas!*  
but key bent while trying to turn. Shut off in cellar - Ramos

11/21/91 shut off at curb stop - Souza

INACTIVE SER

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

2-11-66

~~Re~~ Reamed

11/21 91473831

[illegible]

## CHARGE OUTS

[illegible]