

APPLICATION No.: 15855

TAP CLEARED ✓

LOCATION: 567-571 So. First

OWNER: Antonio De Freitas

DATE

BEF.

AFT.

REMARKS

6/6/84

REAMED

MEASURES:

5/8"

N from	Rivet	242.5
E from W line	First	6.2
S from N line	House	2.5

-----  
June 6, 1984 - J.F. Kennedy Hwy. Proj.  
Dow Co. renewed from main to property line.  
13.6 Ft. - 3/4" copper tubing; 1 - 3/4" curb stop;  
1 stop box; 1 - 5/8" x 3/4" Fig. 413;  
1 - 5/8" x 3/4" lead to copper adaptor XS  
-----

11/28/89 shut off at curb - EMPTY

12/4/90 checked - Hansen - still off

INACTIVE SER

[illegible]

## CHARGE OUTS

[illegible]



APPLICATION No.: 15852

## TAP CLEARED

LOCATION:	567 Rear S <sup>o</sup> . First	DATE	BEF.	AFT.	REMARKS
OWNER:	John De Mello	2-11-66			<del>Reamed</del>
MEASURES:	3/4" CLEAR ELECTRIC			11/21	91473831
	N from Rivet 253.4				
	W from Eline Second 6.6				
	N from N line 438-440 Second 5.6				
October 9, 1974 Renewed from 6" outside curb stop to property line.					
9 ft. - 3/4" Copper tubing 3/4" Curb stop					
2 wipe joints Caldwell Stop Box					
-----					
February 11, 1966 Tap Reamed. 1 5/8" reused corporation cplg.					
-----					
Nov. 5, 1991 Request of Div. Min. Housing - Mr. Rawley house flooding leak inside - Blew out box with compressor <sup>com gas!</sup> but key bent while trying to turn. Shut off in cellar - Ramos					
11/21/91 shut off at curb stop - Souza					
INACTIVE SER					

[illegible]

## CHARGE OUTS

[illegible]