

APPLICATION No.: 15876

TAP CLEARED

LOCATION:

4364 Acushnet Ave

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES:

July 16, 1914

S from S line Cresent St 14.2'

W from E line Acushnet Ave 6.9'

N from N line house 5.2'

5/17/95: tap reamed

1" copper

3-26-18: Lead service line replacement program  
phase 1, TYPE CU, Diameter 1, Water Pressure 60

Contractor: P. Gioiosio

Distance from main to curb stop 35'

Distance curb stop to meter 83'

Distance from curb face to curb stop 1'

Depth of service 5'

Total length of new pipe installed 83'

Curb stop replaced: N/A Size N/A

Corporation replaced: N/A Size N/A

Ball valve furnished: YES Size 1"

Remarks: New 1" copper length includes 3ft  
interior connection water meter.

1" x 1" union is located 71ft from curb stop

# METER HISTORY

## CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

lies:

