

APPLICATION No.: 15881

TAP CLEARED ✓

LOCATION: 497-9 Middle

OWNER: Lt. D. Cosmos

MEASURES:

5/8"

07-14-1914

E from

James

84.5 ft.

S from N line

Middle

6.8 ft.

E from W line

House

4.3 ft.

Jan. 28, 1976 Renewed from 6" outside curb stop to
property line.

7½ ft. - 3/4" Copper tubing

3/4" Curb Stop

1 wipe joint (outside curb stop) Caldwell Stop Box

5/8" x 3/4" lead to copp. adapt. XS

- - -

9/18/08 - West End Water Main Rehab - Contract #4 - Perrina Const.

Renewed service from main to curb stop

19 ft - 1" copper tubing; 1 - 1" corp tap

Inspected by Tim Ives, CDM

12/15/14 city crew repaired leak inside pipe, renewed from 1/2'
outside curb stop to inside cellar 12' inside property line.

forman

jarred medeiros

[illegible]

CHARGE OUTS

[illegible]