

APPLICATION No.: 1594

TAP CLEARED 84391206

LOCATION: 31 Maple

OWNER: William O'Donnell

MEASURES:

3/4"

W from

Cottage

252.2 ft.

S from N line-

Maple

6.5 ft.

W from E line

House

13.5 ft.

Oct. 9, 1967 Renewed from 1/2 ft. outside curb stop to property line.

12 ft. - 3/4" Copper tubing (3/4" Curb stop
3 wipe joints Stop Box
- - -

Sept. 8, 1969 Renewed from the main to a point 4 ft. from the main.

4 ft. - 3/4" Copper tubing 1" x 3/4" Fig. 413
1 wipe joint - - -

Sept. 26, 1984: Renewed from curb stop to a point 1.6 ft. outside curb stop. Stock: 1.5 ft. 3/4" copper tubing
1 3/4" curb stop 1 #1 Caldwell stop box 1 lead to
cop adapt. comp. XXS

12/24/87 Rusty water outside spigot clear water
clear water 1st floor kitchen. 2nd fl bathroom
rusty 9 buckets

DATE

BEF.

AFT.

REMARKS

9/8/69

Reamed

[illegible]

CHARGE OUTS

[illegible]

CARD #2

APPLICATION No.: 1594

LOCATION: 31 Maple St.

OWNER:

31-313

MEASURES:

| | | |
|---------------|---------|----------|
| W from | Cottage | 252.2 ft |
| S from N line | Maple | 6.5 ft |
| W from E line | House | 13.5 ft |

September 29, 2015 City crew repaired tap leak,
stock: 19' 3/4 cop, corp adapt, 3/4 curb stop valve
Foreman J. Medeiros *Renewed main to prop line*

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

METER HISTORY

[illegible]

CHARGE OUTS