APPLICATION No.: 15942	TAP CLEARED			
LOCATION: 71 - 73 Mt. Vernon St	DATE	BEF.	AFT.	REMARKS
OWNER:				
MEASURES: W X Highland St S X N Line Mt. Vernon St W X E Line House 9.6 ft 1" Copper Service 05/15/2019 Lead Service Replacement Program Phase 1, Contractor P Gioioso & Son Type CU, Diameter 1in, Water pressure 50 Distance from main to curb stop (ft) 19 Distance from curb stop to meter (ft) 18.4 Distance from curb face to curb stop (ft) 1.7 Depth of service (ft) 4.1 Total length of new pipe installed (ft) 18.4 Curb stop replaced: no size 3/4" Corporation replaced: no size 3/4" Ball valve replaced: yes size 1" Remarks: 1-3/4" union installed 1 ft outside curb stop				

