

B.P.M.-NBIS 702-14

APPLICATION No.: 15960

TAP CLEARED ✓

LOCATION: Purchase N.E. Cor. SpringOWNER: Maynard A Dais

MEASURES: 4"

FIRE SUPPLY

Chapman gate wood box covers 2 gates # 15959 & 15960

N from N line Spring 57.6 ft.

W from E line Purchase 10.3 ft.

N from S line Bldg. 57.6 ft.

37 ft. 4" C.I. pipe including specials.

Sept. 30, 1973 Relocated 4" gate closer to water main.
 Inserted a 3 ft. piece of pipe in old location of gate
 with two Smith Blair Cplgs.

5½ ft. - 4" C.I. Pipe S&S

4" Mueller Gate Valve AB

4" Gate Box, Reg.

2 - 4" leadite joints

5/8" Asbestos

4 - 4" Smith Blair cplg.
Style #441Measures for Mueller Gate Valve

N x N line Spring St.

57.5 ft.

S x N line Bldg.

48.3 ft.

W x E line Purchase St.

30.6 ft.

W x W line Bldg.

30.6 ft.

Measures for Smith Blair cplg. at gate

W x E line Purchase St.

29.1 ft.

W x E line Purchase St.

32.1 ft.

Measures for Smith Blair cplg. for spacer

W x E line Purchase St.

10.0 ft.

W x E line Purchase St.

13.0 ft.

[illegible]

CHARGE OUTS

[illegible]