

APPLICATION No.: 159699TAP CLEARED 8406 0615LOCATION: 234 HawthornOWNER: Mary L. DohertyMEASURES: 5/8"

E from Brigham 26.0 ft.

N from S line Hawthorn 8.4 ft.

E from W line house 16.0 ft.

Feb. 8, 1984 - Renewed from $\frac{1}{2}$ ft. outside curb stop
to property line.

6 $\frac{1}{2}$ ft. - 3/4" copper tubing

1 - 3/4" curb stop 1 stop box

2 - 5/8" x 3/4" lead to copper adaptors XS

NOTE: While repairing leak on 5/19/87 found this service to have
lead from the curb stop toward the property line. Above report
must have been renewed from $\frac{1}{2}$ ft. outside curb stop to curb stop only.

5/19/87: Renewed from main to curb stop (2ft. inside curb stop)

Stock: 10ft. 3/4" copper tubing 1-3/4" curb stop 1-Caldwell
stop box 1-3/4 x 5/8 lead to cop adapt. xs 1-3/4 x 5/8 Fig. 413
=====

DATE BEF. AFT. REMARKS ✓

5/19/87: TAP REAMED

8721-1392

[illegible]

CHARGE OUTS

[illegible]