

APPLICATION No.: 16022

TAP CLEARED

8506-1266

LOCATION: B 150 Rotch

OWNER: Teresa A Nunes

MEASURES:

5/8"

S from

Court

64.0 ft.

W from E line

Rotch

8.5 ft.

S from N line

House

8.0 ft.

2/10/85 Renewed from 1/2' outside curb stop to a point
4.0 ft. Stock: 4.5ft. 3/4" copper tubing 1 3/4" curb
stop 1 Caldwell stop box 2 3/4x5/8 lead to cop adapt. xs

DANGER: 12" H.P. GAS MAIN ON CENTER OF
SIDEWALK RUNNING NORTH AND SOUTH

Feb 3, 1988:

Renewed from main to curb stop

Stock: 26ft-3/4" copper tubing 1-3/4x5/8 Fig 413

=====

May 20, 1996 Riley Exc. working for Comm Gas damaged water service.
Renewed from a point 12 ft. west of existing curb stop to a point 13.5 ft.
1.5 ft. - 3/4" copper tubing 1 - 3/4" curb stop
1 - 3/4" x 3/4" cop to cop cplg., comp.

11/96 M. Pavao Const. renewed from main to curb stop. All stock su
supplied & installed by Contractor. 9 ft. - 3/4" Copper tubing,
1 - 3/4" Curb Stop. M. Pavao to maintain cut.

6-16-98 Biszko Cont renewed service from the newly installed 8" ductile
main to a point 2 ft from the main. Stock supplied by Contractor:
2 ft - 3/4" Copper tubing, 1 - 3/4" x 3/4" cop to cop cplg comp,
1 - 3/4" Corporation tap. Contractor to maintain cut

DATE

BEF.

AFT.

REMARKS

2/3/88: tap reamed

2/8

8805-0798

[illegible]

CHARGE OUTS : 104